

DECLARATION of PERFORMANCE

Number: CPR-24-001

1. Unique identification code of the product:

Type	Nominal voltage	Number of conductors	Conductor section (mm ²)
H05VV-F	300/500 V	2 - 5	0.75 – 6.0

2. Intended use of the product:

The cables are intended for the connection of domestic appliances to the fixed supply, installation in walls, on boards. The flexibility of the cable facilitates installation.

It is used in dry and humid environments where the risk of mechanical damage is low

3. Manufacturer:

PROMEL CABLE LLC Georgia, Tbilisi, Chitaia street, No:7

4. System of assessment and verification of constancy of performance of the product

System 3

The range of cables described in 1&2 belongs to Euroclass Eca

5. Notified Body: EFECTIS ERA AVRASYA TEST VE BELGELENDİRME A.Ş./NR 2184 performed the classification of reaction to fire in accordance with EN 13501-6:2014 test report under system 3 and issued ERA-23-296 & FTST231241, FTST231242 test reports.

6. Declared Performance

Essential characteristics	Performance	Harmonized Technical Specification
Reaction to fire	Eca	EN 50575:2014/A1:2016
Dangerous substances	NPD (No performance determined)	

7. The performance of the product defined is suitable for the performance declared in Article 6.

The performance of the product identified above is in conformity with the set of declared performances. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and in name of the manufacturer by:

Director:

Date:

Giorgi Kilasonia

20.09.2024

PROMEL CABLE LLC

Georgia, Tbilisi, Chitaia street, No:7

tel: +995 574 73 00 63

mail: promelge@gmail.com

www.promelcable.ge

